



Lead and Copper - 90th PERCENTILE COMPLIANCE Report

(For Systems Required to Collect More Than 5 Samples)

I. PWS INFORMATION: Please refer to your DEP Lead & Copper sampling plan for approved sampling locations.

PWS ID #:	1113003	City / Town:	Great Barrington	
PWS Name:	Housatonic Water Works Company	PWS Class:	COM <input checked="" type="checkbox"/>	NTNC <input type="checkbox"/>
Sampling Frequency: (choose one)	<input type="checkbox"/> FIRST SEMI-ANNUAL SAMPLING PERIOD	<input type="checkbox"/> REDUCED - EVERY THREE YEARS		
	<input checked="" type="checkbox"/> SECOND SFMI-ANNUAL SAMPLING PERIOD	<input type="checkbox"/> LEAD SERVICE LINE (LSL) REPLACEMENT PROGRAM		
	<input type="checkbox"/> REDUCED - ANNUAL	<input type="checkbox"/> DEMONSTRATION		

Step 1: Place lead results in ascending order (from lowest to highest value) with lowest value at # 1, in the table below. Repeat for copper results. Please report results that are ND or less than (<) the laboratory's reported detection limit (MDL) as zero. Results at or above the laboratory's detection limit (MDL) but below 0.005 mg/L for lead or 0.05 mg/L for copper shall be reported as measured or may be reported as 0.0025 mg/L for lead or 0.025 mg/L for copper.

Step 2: Multiply the total number of samples collected by 0.9 (this is your 90th percentile sample number). Round to the nearest whole number, if necessary.

Step 3: Compare the sample result at the 90th percentile sample number against the corresponding action level. If the 90th percentile value is higher than the action level, then you have an exceedance and are required to contact MassDEP as soon as possible for information on compliance actions.

Note: Do not include school results on this form unless the PWS is a school. Remember, within 30 days of receipt, you must send individual results to the persons served at each sampled location as per 310 CMR 22.06B(6)(c)¹.

LEAD RESULTS (mg/L)							
#	Results	#	Results	#	Results	#	Results
1*	ND	16	ND	31		46	
2	ND	17	ND	32		47	
3	ND	18	ND	33		48	
4	ND	19	ND	34		49	
5	ND	20	ND	35		50	
6	ND	21		36		51	
7	ND	22		37		52	
8	ND	23		38		53	
9	ND	24		39		54	
10	ND	25		40		55	
11	ND	26		41		56	
12	ND	27		42		57	
13	ND	28		43		58	
14	ND	29		44		59	
15	ND	30		45		60	

COPPER RESULTS (mg/L)							
#	Results	#	Results	#	Results	#	Results
1*	.0020	16	.0101	31		46	
2	.0034	17	.0115	32		47	
3	.0038	18	.0145	33		48	
4	.0043	19	.0191	34		49	
5	.0045	20	.0613	35		50	
6	.0047	21		36		51	
7	.0049	22		37		52	
8	.0054	23		38		53	
9	.0055	24		39		54	
10	.0059	25		40		55	
11	.0064	26		41		56	
12	.0069	27		42		57	
13	.0071	28		43		58	
14	.0074	29		44		59	
15	.0081	30		45		60	

*Lowest Value

My system was required to collect: 20 lead and copper samples. My system collected: 20 lead and copper samples.

Total # of samples collected: 20 x 0.9 = 18 This number is my system's 90th percentile sample #.

Circle the 90th percentile sample # for both lead and copper in the table above, and enter the results in the appropriate spaces below.

<u>ND</u> <small>(Lead result at 90th percentile sample#)</small>	Compared to <u>0.015 mg/L</u> <small>(The lead action level)</small>	<u>.0145</u> <small>(Copper result at 90th percentile sample#)</small>	Compared to <u>1.3 mg/L</u> <small>(The copper action level)</small>
---	---	--	---

II. CERTIFICATION:

Check and complete the correct statement for lead as determined by the above results. If you have an exceedance and you are a community system you must comply with the Consumer Confidence Rule (CCR) reporting requirements in accordance with 310 CMR 22.16A(4)(i)6.

- My system was **at or below** the lead action level.
- My system **exceeded** the lead action level and _____ sampling sites **exceeded** the lead action level.
(Insert # of samples)

Check and complete the correct statement for copper as determined from the above results. If you have an exceedance and you are a community system you must comply with the Consumer Confidence Rule (CCR) reporting requirements in accordance with 310 CMR 22.16A(4)(i)6.

- My system was **at or below** the copper action level.
- My system **exceeded** the copper action level and _____ sampling sites **exceeded** the copper action level.
(Insert # of samples)

My signature below indicates that all sampling sites on this report have been previously approved in writing by the DEP, and both the sites and sampling procedures used comply with 310 CMR 22.06B(7). I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Treasurer	Signature of PWS or Owner's Representative	01/09/2024
<small>Title</small>		<small>Date</small>

Please submit Form LCR-C along with this form.

Rev. 02- 2019

Page 1 of 1

¹ The Consumer notification form template is available at: [https://www.mass.gov/lists/lead-and-copper-forms-and-templates#lead-and-copper-rule-\(lcr\)-](https://www.mass.gov/lists/lead-and-copper-forms-and-templates#lead-and-copper-rule-(lcr)-)