

Housatonic Water Company – Water Discoloration Monitoring and Sampling Program

Housatonic Water Company is committed to ensuring the safety and quality of our community's water supply. We have established a formal program to monitor, document, and respond to reports of water discoloration within our distribution system.

Complaint Documentation

- All water discoloration complaints will be recorded using a standardized complaint form.
 - The form will include:
 - Customer location
 - Quadrant location (based on our nine-quadrant distribution map)
 - Discoloration severity rating (1 = lowest, 5 = highest)
-

Sampling Plan

- Our sampling program reflects the geographic diversity of complaints received.
 - If three or more water discoloration complaints are reported in a single quadrant, Housatonic Water Company will initiate targeted water sample collection in that section of the distribution system.
 - Sampling and laboratory analysis will be performed by an independent third-party vendor.
-

Reporting of Results

- Laboratory test results will be submitted simultaneously to:
 - Massachusetts Department of Environmental Protection
 - Great Barrington Board of Health
 - Housatonic Water Works Company
- A log of all water discoloration reports throughout the system is maintained and updated weekly on our website to reflect the most recent complaints received.
- Lab testing results will also be posted .

Additional Information

To support customer understanding of service areas:

- A map of the distribution system shows the quadrant boundaries.
 - A list of streets contained within each quadrant provides detailed reference information.
-

Commitment to Customers

We value transparency and public health. Customers are encouraged to report any instances of water discoloration immediately.


For questions or to report water discoloration, please contact:
Housatonic Water Company

413.528.1780

housatonicwater@gmail.com

Water Discoloration Log

August 1, 2025 - August 22, 2026



Date	Quad	Color (1-5)	Test ? (Y/N)
Aug 1			
Aug 2			
Aug 3			
	IB		
Aug 4			
	IB		
Aug 5			
	IB	5	
	IB	2	
Aug 6			
IB Tested 8/15		5	Y
Aug 7			
	IIB	4	
Aug 8			
Aug 9			
Aug 10			
Aug 11			
Aug 12			
IIB Tested 8/15		4	Y
	IC		
Aug 13			
Aug 14			
Aug 15			
	IB		
Aug 16			
Aug 17			
Aug 18			
Aug 19			
Aug 20			
	IB	4	
Aug 21			
Aug 22			
Aug 23			
Aug 24			
Aug 25			
	III C	2	
Aug 26			
Aug 27			
	IB	4	
Aug 28			
Aug 29			
	II B	3	
Aug 30			
	II B	3	
Aug 31			
	II B	3	
Sep 1			
	IB	3	
Sep 2			

	IB	3	
Sep 3			
	IB	3	
Sep 4			
	IC	5	
	IB	3	
Sep 5			
Sep 6			
Sep 7			
Sep 8			
Sep 9			
Sep 10			
	II B		
	II A	4	
	I C	3	
	I B	3	
Sep 11			
	1B	4	
Sep 12			
	II A	4	
	1B	4	
Sep 13			
	1B	4	
Sep 14			
	1B	4	
Sep 15			
	1B	3	
	IB	4	
	1B	4	
Sep 16			
	II C	5	
	I A	4	
	II A	4	
Sep 17			
Sep 18			
Sep 19			
Sep 20			
Sep 21			
Sep 22			
Sep 23			
Sep 24			
Sep 25			
Sep 26			
Sep 27			
Sep 28			
Sep 29			
Sep 30			
Oct 1			
Oct 2			
	IIB	3	
Oct 3			
	IIB	3	
Oct 4			
Oct 5			
Oct 6			
Oct 7			
Oct 8			
Oct 9			
Oct 10			
	IIB	3	
Oct 11			
Oct 12			
Oct 13			
Oct 14			
	IIB	5	
	IIB	4	
Oct 15			
	IIB	5	
	IIB	4	
	IIB	5	

Oct 16			
	IIB	5	
	IIB	5	
	IIB	4	
Oct 17			
Oct 18			
Oct 19			
Oct 20			
Oct 21			
Oct 22			
Oct 23			
Oct 24			
Oct 25			
Oct 26			
Oct 27			
Oct 28			
Oct 29			
Oct 30			
Oct 31			
Nov 1			
Nov 2			
Nov 3			
Nov 4			
Nov 5			
Nov 6			
Nov 7			
Nov 8			
Nov 9			
Nov 10			
Nov 11			
Nov 12			
	IB	2	
Nov 13			
Nov 14			
Nov 15			
Nov 16			
Nov 17			
Nov 18			
Nov 19			
Nov 20			
Nov 21			
Nov 22			
Nov 23			
Nov 24			
Nov 25			
Nov 26			
Nov 27			
Nov 28			
Nov 29			
Nov 30			
Dec 1			
Dec 2			
Dec 3			
Dec 4			
Dec 5			
Dec 6			
Dec 7			
Dec 8			
Dec 9			
Dec 10			
Dec 11			
Dec 12			
Dec 13			
Dec 14			
Dec 15			
Dec 16			
Dec 17			
Dec 18			
Dec 19			
Dec 20			
Dec 21			

Dec 22			
Dec 23			
Dec 24			
Dec 25			
Dec 26			
Dec 27			
Dec 28			
Dec 29			
Dec 30			
Dec 31			
Jan 1			
Jan 2			
Jan 3			
Jan 4			
Jan 5			
Jan 6			
Jan 7			
Jan 8			
Jan 9			
Jan 10			
Jan 11			
Jan 12			
Jan 13			
Jan 14			
Jan 15			
Jan 16			
	III B	2	
	II B	3	
	II B	3	
	II B	3	
Jan 17			
Jan 18			
Jan 19			
Jan 20			
Jan 21			
Jan 22			
Jan 23			
Jan 24			
Jan 25			
Jan 26			
Jan 27			
Jan 28			
Jan 29			
Jan 30			
Jan 31			
Feb 1			
Feb 2			
Feb 3			
Feb 4			
Feb 5			
Feb 6			
Feb 7			
Feb 8			
Feb 9			
Feb 10			
Feb 11			
Feb 12			
Feb 13			
Feb 14			
Feb 15			
Feb 16			
Feb 17			
Feb 18			
Feb 19			
Feb 20			
Feb 21			
Feb 22			
Feb 23			
Feb 24			
Feb 25			
Feb 26			
Feb 27			


Feb 28			
Mar 1			
Mar 2			
Mar 3			
Mar 4			
Mar 5			
Mar 6			
Mar 7			
Mar 8			
Mar 9			
Mar 10			
Mar 11			
Mar 12			
Mar 13			
Mar 14			
Mar 15			
Mar 16			
Mar 17			
Mar 18			
Mar 19			
Mar 20			
Mar 21			
Mar 22			
Mar 23			
Mar 24			
Mar 25			
Mar 26			
Mar 27			
Mar 28			
Mar 29			
Mar 30			
Mar 31			
Apr 1			
	IB		
	IIA		
	IIB		
	IIB		
	IIA		
	IIIB		
	IIB		
Apr 2			
	IIB		
	IIB		
	IIB		
	IIB		
	IIB		
	IIA		
	IIIA		
	IIB		
	IIB		
	IIC		
	IIB		
	IIA		
	IIB		
	IIB		
	IIB		
	IIC		
	IIB		
	IIB		
	IIB		
	IIB		
	IIA		
	IIB		
Apr 3			
Apr 4			
Apr 5			
Apr 6			

Apr 7	
Apr 8	
Apr 9	
Apr 10	
Apr 11	
Apr 12	
Apr 13	
Apr 14	
Apr 15	
Apr 16	
Apr 17	
Apr 18	
Apr 19	
Apr 20	
Apr 21	
Apr 22	
Apr 23	
Apr 24	
Apr 25	
Apr 26	
Apr 27	
Apr 28	
Apr 29	
Apr 30	
May 1	
May 2	
May 3	
May 4	
May 5	
May 6	
May 7	
May 8	
May 9	
May 10	
May 11	
May 12	
May 13	
May 14	
May 15	
May 16	
May 17	
May 18	
May 19	
May 20	
May 21	
May 22	
	IB3N
May 23	
May 24	
May 25	
May 26	
May 27	
May 28	
May 29	
May 30	
May 31	
Jun 1	
Jun 2	
Jun 3	
Jun 4	
Jun 5	
Jun 6	
Jun 7	
Jun 8	
Jun 9	
Jun 10	
Jun 11	
Jun 12	
Jun 13	
Jun 14	
Jun 15	
Jun 16	
Jun 17	
Jun 18	
Jun 19	
Jun 20	

Jun 21			
Jun 22			
Jun 23			
Jun 24			
Jun 25			
Jun 26			
Jun 27			
Jun 28			
Jun 29			
Jun 30			
Jul 1			
Jul 2			
Jul 3			
Jul 4			
Jul 5			
	I C	3	N
Jul 6			
	I C	3	N
Jul 7			
	IIB	3	N
	I C	3	N
Jul 8			
	IIB	3	N
	I C	3	N
Jul 9			
	IIB	3	N
	I C	3	N
Jul 10			
	I C	3	N
	III B	2	N
	IIB	3	N
	II B	3	N
	IIIB	3	N
Jul 11			
	I C	3	N
Jul 12			
	I C	3	N
Jul 13			
	I C	3	N
Jul 14			
	I C	3	N
Jul 15			
	I C	3	N
Jul 16			
	I C	3	N
Jul 17			
	I C	3	N
Jul 18			
	I C	3	N
Jul 19			
	I C	3	N
Jul 20			
	I C	3	N
Jul 21			
	I C	3	N
	IIB		N
Jul 22			
Jul 23			
	IC		N
	IIB		N
Jul 24			
Jul 25			
Jul 26			
Jul 27			
Jul 28			
Jul 29			
Jul 30			
Jul 31			
Aug 1			
Aug 2			
Aug 3			

Aug 4			
Aug 5			
Aug 6			
Aug 7			
Aug 8			
Aug 9			
Aug 10			
Aug 11			
	I C	3	N
Aug 13			
Aug 14			
Aug 15			
Aug 16			
Aug 17			
	II B	3	N
Aug 18			
Aug 19			
Aug 20			
Aug 21			
Aug 22			

Distribution Map



I A – North Plain Road - Great Barrington Road

From #279 to #317

Including side streets:

- Long Pond Road
 - Robin Road
 - Water Street (in West Stockbridge)
-

I B – North Plain Road

From #273 to #415

Including side streets:

- Brookside Court
 - Comstock Lane
 - Crimson Lane
 - Linda Lane
 - Wyantenuck Street
-

I C – North Plain Road

From #231 to #271

#54 Division Street to #165 Division Street

Including side streets:

- Grant Lane
 - Lucky Lane
 - Wright Lane
-

II A – Van Deusenville Road- High Street

From #7 to #64

II B – Van Deusenville Road-Core of Town (1011 Main Street to 1099 Main Street)

Including side streets:

- Cottage Street
 - Depot Street
 - Fairview Street
 - Forrest Street
 - Hart Street
 - Highland Street
 - Kirk Street
 - Meadow Lane
 - Meadow Street
 - North Street
 - Oak Street
 - Pine Street
 - Pleasant Street
 - Prospect Street
 - Ryan Terrace
 - South Street
 - Front Street
-

II C – Van Deusenville Road

From #10 to #97

Including side streets:

- Nolan Drive
 - Williams Street
-

III A Park Street- Glendale Road

From #50 to #62

Including side streets:

- Apple Street
 - Housatonic Court
 - North Housatonic Court
-

III B – Park Street

From #302 to #430

Including side streets:

- Bernard Gibbons Drive
 - Chestnut Ridge
 - Cone Avenue
 - Grove Street
 - Mountain View Avenue
 - Waubeck Street
-

IIIC – Park Street

From #298 to #115

Including side streets:

- Maple Street
- Ramsdell Road
- Spruce Street
- Walnut Street

Housatonic Water Company – Water Discoloration Monitoring and Sampling Program

The Housatonic Water Company is committed to ensuring the safety and quality of our water supply. If you experience discolored water, please either call us at (413) 528-1780 or complete this intake form and email it to housatonicwater@gmail.com.



Housatonic Water Works Company Water Discoloration Intake Form

Date: _____

1. Name: _____

2. Address: _____

3. Type of Residence:

☐ Single-family ☐ Multi-family ☐ Apartment ☐ Other: _____

4. Known Plumbing:

Service Line Materials (check all that apply):

☐ Copper ☐ Plastic (PVC/PEX) ☐ Galvanized Iron ☐ Unknown

☐ Other: _____

Interior Plumbing Materials (check all that apply):

☐ Copper ☐ Plastic (PVC/PEX) ☐ Galvanized Iron ☐ Unknown

☐ Other: _____


5. Frequency of Discolored Water in 2025

How often have you experienced discolored water this year?

6. Approximate Dates of Occurrence (if known):

7. Water Appearance

Please circle the photo below that most closely resembles the color of the water you observed:



Example: A: Clear B: Light Yellow C: Orange D: Brown E: Dark Brown

Additional Comments (optional):

Test Results

The test results presented in this section summarize water quality monitoring. Parameters analyzed include color, iron, manganese, and other indicators relevant to tracking water discoloration. These results offer insights into both aesthetic and operational aspects of water quality, helping to identify potential sources of discoloration and ensure compliance with monitoring requirements.



Massachusetts Department of Environmental Protection - Drinking Water Program
Secondary Contaminant Report

SEC

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

AUGUST TEST RESULTS QUADRANT IB

DEP LOCATION (LOC) ID#	DEP Location Name North Plain Road	Sample Information ☐ (M)ultiple ☒ (S)ingle ☐ (R)aw ☒ (F)inished	Date Collected 08/15/25	Collected By Erick Bartlett
Routine or Special Sample ☐ RS ☒ SS	Original, Resubmitted or Confirmation Report ☐ Original ☐ Resubmitted ☐ Confirmation	If Resubmitted Report, list below (1) Reason for Resubmission ☐ Resample ☐ Reanalysis ☐ Report Correction (2) Collection Date of Original Sample		
SAMPLE NOTES - (Such as, if a Manifold/Multiple sample, list the sources that were on-line during sample collection).				

II. ANALYTICAL LABORATORY INFORMATION

Primary Lab MA Cert. #: M-MA1146 Primary Lab Name: Microbac Laboratories, Inc., Lee Subcontract? (Y/N) Y

Contaminant	Result	Result Qualifier	SMCL	Lab MDL	Lab MRL	Dilution Factor	Lab Method	Date Analyzed	Analysis Lab MA Cert. #	Analysis Lab Sample ID#
ALKALINITY (CaCO ₃), TOTAL (mg CaCO ₃ /L)	77.5		None	1.00	1.00	1.00	SM 2320 B-1997	08/21/2025	M-CT008	E5H0357-02
COLOR (CU)	40	Y1	15	1	1	1.00	SM 2120 B-2001	08/15/2025	M-CT008	E5H0357-02
IRON (mg/L)	ND		0.3	0.00428	0.0500	1.00	EPA 200.7, Rv. 4.4 (1994)	08/18/2025	M-CT008	E5H0357-02
MANGANESE (mg/L)	0.0662		0.05*	0.000584	0.00204	1.00	EPA 200.7, Rv. 4.4 (1994)	08/18/2025	M-CT008	E5H0357-02
TURBIDITY (NTU)	0.64		None		0.20	1.00	SM 2130 B-2001	08/15/2025	M-CT008	E5H0357-02
TOTAL DISSOLVED SOLIDS (mg/L)	133		500		10.0	1.00	SM 2540 C-1997	08/20/2025	M-CT008	E5H0357-02

* EPA has established a lifetime Health Advisory (HA) for manganese at 0.3 mg/L and an acute HA at 1.0 mg/L.

Lab Analysis Comments	Result Qualifier	Result Qualifier Description
	Y1	Accreditation is not offered by the accrediting body for this analyte.

I certify under penalties of law that I am the person
authorized to fill out this form and the information contained herein is
true, accurate and complete to the best extent of my knowledge

Primary Lab Director Signature:

Date: 8/25/2025

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.

DEP REVIEW STATUS (Initial & Date) ☐ Accepted ☐ Disapproved	Review Comments	☐ WQTS Data Entered
--	--------------------	---



Massachusetts Department of Environmental Protection - Drinking Water Program
Secondary Contaminant Report

SEC

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

AUGUST TEST RESULTS QUADRANT IIB

DEP LOCATION (LOC) ID#	DEP Location Name Main Street	Sample Information ☐ (M)ultiple ☒ (S)ingle ☐ (R)aw ☒ (F)inished	Date Collected 08/15/25	Collected By Erick Bartlett
Routine or Special Sample ☐ RS ☒ SS	Original, Resubmitted or Confirmation Report ☐ Original ☐ Resubmitted ☐ Confirmation	If Resubmitted Report, list below (1) Reason for Resubmission ☐ Resample ☐ Reanalysis ☐ Report Correction (2) Collection Date of Original Sample		
SAMPLE NOTES - (Such as, if a Manifold/Multiple sample, list the sources that were on-line during sample collection).				

II. ANALYTICAL LABORATORY INFORMATION

Primary Lab MA Cert. #: M-MA1146 Primary Lab Name: Microbac Laboratories, Inc., Lee Subcontract? (Y/N) Y

Contaminant	Result	Result Qualifier	SMCL	Lab MDL	Lab MRL	Dilution Factor	Lab Method	Date Analyzed	Analysis Lab MA Cert. #	Analysis Lab Sample ID#
ALKALINITY (CaCO ₃), TOTAL (mg CaCO ₃ /L)	77.5		None	1.00	1.00	1.00	SM 2320 B-1997	08/21/2025	M-CT008	E5H0357-01
COLOR (CU)	40	Y1	15	1	1	1.00	SM 2120 B-2001	08/15/2025	M-CT008	E5H0357-01
IRON (mg/L)	ND		0.3	0.00428	0.0500	1.00	EPA 200.7, Rv. 4.4 (1994)	08/18/2025	M-CT008	E5H0357-01
MANGANESE (mg/L)	0.102		0.05*	0.000584	0.00204	1.00	EPA 200.7, Rv. 4.4 (1994)	08/18/2025	M-CT008	E5H0357-01
TURBIDITY (NTU)	0.94		None		0.20	1.00	SM 2130 B-2001	08/15/2025	M-CT008	E5H0357-01
TOTAL DISSOLVED SOLIDS (mg/L)	102		500		10.0	1.00	SM 2540 C-1997	08/20/2025	M-CT008	E5H0357-01

* EPA has established a lifetime Health Advisory (HA) for manganese at 0.3 mg/L and an acute HA at 1.0 mg/L.

Lab Analysis Comments	Result Qualifier	Result Qualifier Description
	Y1	Accreditation is not offered by the accrediting body for this analyte.

I certify under penalties of law that I am the person
authorized to fill out this form and the information contained herein is
true, accurate and complete to the best extent of my knowledge

Primary Lab Director Signature: 

Date: 8/25/2025

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.

DEP REVIEW STATUS (Initial & Date) ☐ Accepted ☐ Disapproved	Review Comments	☐ WQTS Data Entered
--	--------------------	---



Lead and Copper Water Quality Parameter Report

Initial Sampling

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: 1113003 City / Town: Gt. Barrington Sample Collection Date: 08/15/2025

PWS Name: Housatonic Water Works PWS Class: COM ☒ NTNC ☐ TNC ☐

Number of Distribution Samples Required:

Number of Distribution Tap Samples Submitted:

Number of Entry Point Samples Required:

Number of Entry Point Samples Submitted:

SAMPLE NOTES**II. ANALYTICAL LABORATORY INFORMATION**

Sample Site Address	Field Parameters		Parameter				
	pH	Temperature (°F)	Alkalinity (mg/L)	Conductivity (µmho/cm)	Calcium (mg/L)	Orthophosphate* (mg/L)	Silica* (mg/L)
Main Street	7.70	70.1	77.5				
North Plain Road	7.60	68.9	77.5				

* Required when using corrosion control inhibitor containing phosphate or silicate compounds.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge

Primary Lab Director Signature:

Date: 8/25/2025

If not submitting results electronically, mail TWO copies of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

DEP REVIEW STATUS (Initial & Date)	Review Comments	☐ WQTS Data Entered
☐ Accepted ☐ Disapproved		



MassDEP Fact Sheet

Manganese in Drinking Water: Questions and Answers for Consumers

Introduction

This fact sheet is intended to inform you about manganese in drinking water, typical concentrations, its contribution to overall manganese exposure in humans, especially infants, and provide guidance on health protective limits in drinking water.

What is manganese and where does it come from?

Manganese is a common naturally-occurring mineral found in rocks, soil, groundwater, and surface water. It is a natural component of most foods and is necessary for proper nutrition. It is also present in infant formulas.

How are people exposed to manganese?

Manganese exposures can come from air, food or water. This fact sheet focuses on water. The majority of manganese exposure in the general population comes from the diet. Grains, beans, nuts and teas in particular are rich in manganese. It is an **essential** trace mineral for the body to function, however excess manganese exposure has potential health implications.

In situations where manganese levels in drinking water are elevated, the contribution from drinking water can increase the overall intake of manganese.

In a residential setting, breathing in manganese is an unlikely route of concern for exposure, in contrast to certain occupational settings where workers may be exposed to manganese particles in the air (*e.g.*, steel welding). Manganese is poorly absorbed through the skin, thus, skin contact with food or liquid containing manganese is an unlikely exposure route of concern.

What health effects are associated with exposure to manganese?

Manganese is necessary for normal immune system function, digestion and bone strength. At elevated levels, manganese could produce neurological effects with some variation in sensitivity between individuals.

Infants and children younger than 12 months old are potentially most susceptible to excess manganese exposure because of their developing neurological and gastrointestinal systems. Infants appear to absorb more manganese than older age children and adults, but excrete less.

If infant formulas are prepared with water that also contains manganese at concentrations greater than our guideline levels (see below), the infant may get a higher amount of manganese than necessary. This represents a greater potential for exposure and adverse effects in the very young. Thus, it is very important to know what the levels in drinking water are when using it to make baby formula.

What are the levels of concern?

The United States Environmental Protection Agency (US EPA) and MassDEP currently list manganese as a secondary contaminant because of aesthetic concerns including unacceptable taste, staining of fixtures and dark, cloudy water at levels greater than 0.05 milligrams per liter (mg/L).

MassDEP recommends that infants up to 1 year of age should not be given water with manganese concentrations greater than 0.3 mg/L for more than a total of 10-days in a year, nor should the water be used to make formula for more than a total of 10-days in a year.

The recommended water concentration limit for lifetime exposures to manganese is 0.3 mg/L. People may also want to limit consumption of waters containing greater than 1 mg/L. See the MassDEP Advisory at: <https://www.mass.gov/doc/massdep-office-of-research-and-standards-guideline-orsg-for-manganese/download> Individual requirements for, as well as adverse effects from, manganese can be highly variable. The general population water concentration exposure limits of 0.3 and 1 mg/L have been set based upon typical daily dietary manganese intake levels not known to be associated with adverse health effects. This does not imply that intakes above these levels will necessarily cause health problems. As a precaution, the general population should consider limiting their consumption of drinking water with high levels of manganese to decrease their exposures and to decrease the possibility of adverse neurological effects.

Should I be concerned if I am pregnant or am breastfeeding my child if the manganese levels are above 0.3 mg/L?

No. There is no correlation between manganese levels in water and manganese levels in breast milk and hence, if you are healthy and breastfeeding you should continue to do so. If you are pregnant, have significant health issues and/or are concerned, you should talk to your health care provider and bring a copy of this fact sheet with you.

How does manganese get into my drinking water?

Water that is used as a source of drinking water invariably has some natural manganese in it. In addition, minerals such as manganese can settle out and build up as fine sediment in water pipes as water flows through the distribution system of water mains to your tap. When there is a disturbance in the system, such as a water main break, use of fire hydrants, or a flushing operation to clean the pipes, sediment may get stirred up and drawn into home plumbing. This water may temporarily have higher than normal levels of manganese and may appear visibly discolored.

Can I cook with the water?

You may reduce your potential exposure to manganese by limiting use of this water and substituting bottled water or water from another low manganese source for preparing dried foods (e.g., pasta, rice, hot oatmeal, etc.) that absorb considerable amounts of water and for soups made with added water.

Can I brush my teeth with the water?

Yes. You are unlikely to ingest enough manganese to be of concern.

Can I bathe, shower or wash my hands with the water? Can I bathe my infant in this water?

Yes. Manganese is poorly absorbed through the skin.

Can I use it to wash dishes?

Yes.

Can I use ice made with the water?

Occasional use of ice for use in drinks represents only a fraction of water consumed daily and will not greatly increase your manganese intake. If you use ice frequently in drinks and your water has high manganese

concentrations, you may choose to use bottled water or water from another low manganese source to make ice or you may just purchase ice.

I have already been using the water for some time for cooking, making ice and drinks. Should I be concerned? Is this something I should go to the doctor about?

See answers to concerns about these uses above. If you have still have concerns or have significant health issues, you should talk to your health care provider. When you meet with them, provide a copy of your manganese sampling results and this fact sheet.

I have used this water to make formula for my baby. Should I be concerned? Is this something I should go to the doctor about?

If you have concerns, you should speak to your health care provider. When you meet with them, provide a copy of your manganese sampling results and this fact sheet.

Can I give the water to my pets?

No information is available on the effect of elevated manganese in drinking water on pets.

How can I find out about manganese in my water?

If you get your water from a public water system you should contact them for this information. For a contact list for all public water systems in the Commonwealth you may visit: <https://www.mass.gov/media/831461/>

For private well owners, MassDEP recommends that a baseline sample be taken to determine the manganese concentration in their well water. Thereafter, the well owner should follow the: "Private Wells - Testing Parameters and Frequency Guidelines", which can be found on the MassDEP website <http://www.mass.gov/eea/agencies/massdep/water/drinking/private-wells.html>. First click on "A guide to water quality testing for private wells" and then scroll down to "Private Wells –Testing Parameters and Frequency Guidelines".

What options are available when manganese in drinking water is elevated?

- You may use:
 - ✓ Bottled water. Bottled water should only be used if it has been tested. The Massachusetts Department of Public Health requires companies licensed to sell or distribute bottled water or carbonated non-alcoholic beverages to test for manganese. See <https://www.mass.gov/info-details/water-quality-standards-for-bottled-water-in-massachusetts> For manganese, the recognized standard is 0.05 mg/L.
 - ✓ Water from another MassDEP approved public water system that does not have elevated levels of manganese.
 - ✓ A water pitcher filter or a home water filter unit that is capable of removing dissolved metals (using a water softener employing cation exchange technology or reverse osmosis; activated carbon units alone have poor manganese removal capabilities). For more information on these types of filter units please visit National Sanitation Foundation (NSF) at NSF Consumer Information (<http://info.nsf.org/Certified/DWTU/>) or call 1-800-673-8010 or visit MassDEP's website <https://www.mass.gov/service-details/home-water-treatment-devices-point-of-entry-and-point-of-use-drinking-water-treatment> for consumer information on home water treatment.
- Do not:
 - ⊗ boil the water as boiling will not destroy manganese. If boiled too long, the manganese will be concentrated in the water.
 - ⊗ freeze or try to filter the water through paper filters to remove manganese as neither will reduce its concentrations.

- ⊙ try to reduce manganese concentrations by letting the water stand overnight since it is not volatile but stays in the water

Please note: Only a Massachusetts state certified laboratory or another party who complies with Massachusetts General Law Chapter 111, Section 160D should test your water for manganese.

<https://eeaonline.eea.state.ma.us/DEP/Labcert/Labcert.aspx>

<https://www.mass.gov/doc/required-disclosure-of-water-test-results-0/download>

Where can I get more information on manganese?

For more information on manganese in public drinking water please see:

- US EPA Drinking Water Health Advisory for Manganese https://www.epa.gov/sites/production/files/2014-09/documents/support_cc1_magnese_dwreport_0.pdf
- CDC ATSDR information on manganese <https://wwwn.cdc.gov/TSP/substances/ToxSubstance.aspx?toxid=23>

You may also contact the MassDEP Drinking Water Program at program.director-dwp@mass.gov

For questions related to manganese exposure and health you may contact MassDEP's Office of Research and Standards (C.Mark.Smith@mass.gov). You may also contact your Local Board of Health and/or your healthcare provider.